

### Lakewood Elementary School Water Test Results

Sample ID	Location code	Location description	Collection Date	Lead ug/L	Comments
BE57272	LAKWOOD_ELEMENTARY	Rm #31 Sink (first draw)	12/13/2018	10	
BE57273	LAKWOOD_ELEMENTARY	K2 North Sink Faucet (first draw)	12/13/2018	ND	
BE57274	LAKWOOD_ELEMENTARY	Rm #16 Sink (first draw)	12/13/2018	9.8	
BE57275	LAKWOOD_ELEMENTARY	Cafeteria West Sink (first draw)	12/13/2018	7.6	
BE57276	LAKWOOD_ELEMENTARY	Lions Club Sink (first draw)	12/13/2018	ND	
BE90717	LAKWOOD_ELEMENTARY	Rm #31 Sink (first draw)	3/21/2018	19	
BE90718	LAKWOOD_ELEMENTARY	Rm #31 Sink (3 min flushing)	3/21/2018	ND	
BE90719	LAKWOOD_ELEMENTARY	Rm #16 Sink (first draw)	3/21/2018	65	
BE90720	LAKWOOD_ELEMENTARY	Rm #16 Sink (3 min flushing)	3/21/2018	ND	
BE90721	LAKWOOD_ELEMENTARY	Cafeteria-West Sink (first draw)	3/21/2018	ND	
BE90722	LAKWOOD_ELEMENTARY	Cafeteria-West Sink (3 min flushing)	3/21/2018	ND	

The EPA recommends lead levels to be at 15 parts per billion (ppb) or below.

ND = Non-detect (lead was not detected)